

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 01:01 pm

PWS ID: UTAH26070 **Name:** CCH2O INC
Legal Contact: CCH2O, INC **Rating:** Not Approved
BRENT WATERMAN **Rating Date:** 07/06/2010
Address: PO BOX 433 **Activity Status:** Active
HEBER CITY, UT 84032
Phone Number: 435-654-5795
City Served (Area):
County: WASATCH COUNTY
System Type: Non-community **Last Inv Update:** 06/15/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 06/05/2008 **Total Dsgn Cap:**
Population: 25 **Surveyor:** DWIGHT HILL **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	WATERMAN, BRENT				

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Commercial	Unknown	0	1
Residential	Unknown	0	5
			6 Total Svc Connections

Storage

Total Storage: 4,500 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	CURRANT CREEK RESERVOIR	Ground	4,500 GAL	Plastic		A	NO
ST002	STORAGE FACILITY ST002	Ground				A	NO

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
		No		

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	CURRANT CREEK LODGE V	Active	WL	8	80 GPM	80 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.